GridVision AI

ERCOT · Texas · Public-record retrospective

Asherton 138 kV: interconnection queue history

Two of four requests withdrew; one reached operation.

Four interconnection requests since 2017: 1 reached commercial operation, 2 withdrew, and 1 remains active.

REQUESTS	BUILT	WITHDRAWN	STILL IN QUEUE	MEDIAN YEARS
4	1	2	1	6.3

THE QUEUE RECORD (SOURCE ROWS)

Requested	Project	Technology	MW	Outcome	Dated
2017-05-02	McLean (Shakes) Solar	Solar	206	Built	2023-09-01
2018-07-17	Robles Storage	Other	100	Withdrawn	2020-03-16
2018-07-17	Robles Solar	Solar	200	Withdrawn	2020-03-16
2021-01-25	Steppe Reserve Storage	Battery	51.9	In queue	—

WHAT THE RECORD SHOWS

- 300 MW of the 558 MW filed here withdrew, and 206 MW reached commercial operation.
- The one request that reached operation took 6.3 years from request to commercial operation.
- The largest request filed here, 206 MW (solar), reached operation 6.3 years after filing.
- Two requests were filed on 2018-07-17; all of them withdrew.

This is a reading of a public dataset, not a customer case study: no engagement, customer or client is involved. The dataset records outcomes — what was built, what withdrew, and when — but not why any project withdrew, so no cause is attributed here. Nothing on this page claims GridVision predicted, influenced or would have changed any outcome, and a pattern at one point of interconnection does not generalise to another.

Source: Lawrence Berkeley National Laboratory, Queued Up: 2026 Edition — project-level interconnection queue dataset. Interconnection requests through year-end 2025. Used under CC BY 4.0; attribution to Lawrence Berkeley National Laboratory and GridTracker. https://gridvisionai.com/retrospectives/ercot-asherton-138-kv