GridVision AI

ERCOT · Texas · Public-record retrospective

Cenizo 345 kV: interconnection queue history

Three of six requests withdrew; one reached operation.

Six interconnection requests since 2015: 1 reached commercial operation, 3 withdrew, and 2 remain active.

REQUESTS	BUILT	WITHDRAWN	STILL IN QUEUE	MEDIAN YEARS
6	1	3	2	7.4

THE QUEUE RECORD (SOURCE ROWS)

Requested	Project	Technology	MW	Outcome	Dated
2015-03-23	Reloj Del Sol Wind	Wind	209.4	Built	2022-08-03
2016-01-04	Zapata II W	Wind	400	Withdrawn	2019-03-20
2019-07-18	Saturn 2 Wind	Wind	150	Withdrawn	2020-09-22
2019-07-18	Saturn 1 Wind	Wind	300	Withdrawn	2020-09-22
2021-05-31	BRP Nile BESS	Battery	202.34	In queue	—
2021-07-13	Quarter Ranch Solar	Solar	154.12	In queue	—

WHAT THE RECORD SHOWS

- 850 MW of the 1,416 MW filed here withdrew, and 209 MW reached commercial operation.
- The one request that reached operation took 7.4 years from request to commercial operation.
- The largest request filed here, 400 MW (wind), withdrew 3.2 years after filing.
- Two requests were filed on 2019-07-18; all of them withdrew.

This is a reading of a public dataset, not a customer case study: no engagement, customer or client is involved. The dataset records outcomes — what was built, what withdrew, and when — but not why any project withdrew, so no cause is attributed here. Nothing on this page claims GridVision predicted, influenced or would have changed any outcome, and a pattern at one point of interconnection does not generalise to another.

Source: Lawrence Berkeley National Laboratory, Queued Up: 2026 Edition — project-level interconnection queue dataset. Interconnection requests through year-end 2025. Used under CC BY 4.0; attribution to Lawrence Berkeley National Laboratory and GridTracker. https://gridvisionai.com/retrospectives/ercot-cenizo-345-kv