GridVision AI

PJM · Ohio · Public-record retrospective

Marysville-Sorenson 765 kV: interconnection queue history

Seven of nine requests withdrew; two are still in the queue.

Nine interconnection requests since 2017: 7 withdrew and 2 remain active.

REQUESTS	BUILT	WITHDRAWN	STILL IN QUEUE	MEDIAN YEARS
9	0	7	2	—

THE QUEUE RECORD (SOURCE ROWS)

Requested	Project	Technology	MW	Outcome	Dated
2017-03-10	(unnamed)	Wind	500.25	Withdrawn	2019-11-07
2020-03-06	Grange Solar	Solar	500	Withdrawn	2025-02-27
2020-04-20	Grange Solar	Battery	200	Withdrawn	2025-02-12
2020-04-20	Grange Solar	Solar + battery	400	Withdrawn	2025-02-12
2020-10-16	(unnamed)	Solar	200	Withdrawn	2024-12-18
2021-09-01	(unnamed)	Solar	55	Withdrawn	2024-12-18
2021-10-07	(unnamed)	Solar	100	In queue	—
2022-03-01	(unnamed)	Solar + battery	119	Withdrawn	2023-07-07
2023-02-27	(unnamed)	Solar	271	In queue	—

WHAT THE RECORD SHOWS

- 1,974 MW of the 2,345 MW filed here withdrew.
- The largest request filed here, 500 MW (wind), withdrew 2.7 years after filing.
- Two requests were filed on 2020-04-20; all of them withdrew.
- None of the 7 withdrawals came within a year of filing; the quickest took 1.3 years.

This is a reading of a public dataset, not a customer case study: no engagement, customer or client is involved. The dataset records outcomes — what was built, what withdrew, and when — but not why any project withdrew, so no cause is attributed here. Nothing on this page claims GridVision predicted, influenced or would have changed any outcome, and a pattern at one point of interconnection does not generalise to another.

Source: Lawrence Berkeley National Laboratory, Queued Up: 2026 Edition — project-level interconnection queue dataset. Interconnection requests through year-end 2025. Used under CC BY 4.0; attribution to Lawrence Berkeley National Laboratory and GridTracker. https://gridvisionai.com/retrospectives/pjm-marysville-sorenson-765-kv